



## Emergency Engine Hours of Operation Tracking Form

Year

**Part I: Unit Information** (provide emergency engine identification, manufacturer and model number information)

Unit ID	Manufacturer	Model Number

**Part II: Unit Hours of Operation** (specify number of hours the identified emergency engine operated in each month)

January	February	March	April	May	June	July	August	September	October	November	December	<b>Total</b>

**Part III: Reason for Operation** (if emergency engine operation is indicated above, provide date and brief explanation for operation)

You may operate an emergency engine under RCSA §22a-174-3b(e) by complying with the following for *each* emergency engine:

- Operate the emergency engine *only* during periods of testing and scheduled maintenance or during an emergency.
- Limit hours of operation to 300 hours during any 12 month rolling aggregate.
- Use fuel with a sulfur content ≤ 0.0015% by weight (15 ppm).
- Make and maintain records of the hours of operation for each month and each 12 month rolling aggregate, including the reason for operation.
- Maintain records of fuel purchases, including fuel sulfur content.
- Maintain records for five years from the date of creation.