



External Combustion Unit Fuel Use Tracking Form

Year

Part I: Unit Information (provide external combustion unit identification, manufacturer and model number information)

Unit ID	Manufacturer	Model Number

Part II: Fuel Information (identify the primary and secondary fuel used in the external combustion unit)

Primary Fuel	Secondary Fuel
<input type="checkbox"/> Distillate Oil (<i>gal</i>) <input type="checkbox"/> Distillate Oil/Biodiesel Blend (<i>gal</i>) <input type="checkbox"/> Natural Gas (<i>MMcf</i>) <input type="checkbox"/> Residual Oil (<i>gal</i>) <input type="checkbox"/> Residual Oil/Biodiesel Blend (<i>gal</i>) <input type="checkbox"/> Propane (<i>gal</i>)	<input type="checkbox"/> Distillate Oil (<i>gal</i>) <input type="checkbox"/> Distillate Oil/Biodiesel Blend (<i>gal</i>) <input type="checkbox"/> Natural Gas (<i>MMcf</i>) <input type="checkbox"/> Residual Oil (<i>gal</i>) <input type="checkbox"/> Residual Oil/Biodiesel Blend (<i>gal</i>) <input type="checkbox"/> Propane (<i>gal</i>)

Part III: Fuel Use (specify the quantity of primary (P) and secondary (S) fuel used in the external combustion unit each month)

	January	February	March	April	May	June	July	August	September	October	November	December	Total
P													
S													

You may operate an external combustion unit under RCSA §22a-174-3b(c) by complying with the following for *each* external combustion unit:

- Restrict fuel use in accordance with the following limitations in any 12 month rolling aggregate:
 - Distillate Oil and Distillate Oil/Biodiesel Blends: ≤ 704,000 gallons (unit ≤ 25 MMBtu/hr).
 - Residual Oil and Residual Oil/Biodiesel Blends (≤ 0.5% sulfur content by weight): ≤ 191,000 gallons (unit ≤ 15 MMBtu/hr).
 - Natural Gas: ≤ 214 million cubic feet (unit ≤ 50 MMBtu/hr).
 - Propane: ≤ 1.57 million gallons (unit ≤ 50 MMBtu/hr).
- Make and maintain records of the fuel type and quantity used, in gallons (*gal*) or million cubic feet (*MMcf*) for each month and each 12 month rolling aggregate.
- Perform a tune-up of the external combustion unit on an annual basis and maintain a record of the date performed.
- Maintain records for five years from the date of creation.