

COMPREHENSIVE APPROACH TO PERFORMANCE IMPROVEMENT AND EMISSIONS REDUCTION ON A 400 MW TANGENTIALLY-FIRED BOILER¹: PART 1 – COMBUSTION OPTIMIZATION

Carlos E. Romero, Nenad Sarunac, and Harun Bilirgen
Energy Research Center
Lehigh University,
Bethlehem, Pennsylvania 18015
610-758-5780

John Bokowski and Michael Cilinski
Bridgeport Generating Station
Bridgeport, Connecticut

ABSTRACT

Combustion optimization of a pulverized coal-fired boiler is a complex process requiring in-depth knowledge of combustion, operation of boiler firing system and other factors affecting emissions and unit performance. For best results, combustion tuning needs to be performed before combustion optimization tests are conducted. Also any, site-specific, operating constraints, such as high CO or opacity, need to be mitigated or removed.

Slagging and sootblowing are important parameters that also need to be considered while performing combustion optimization since they affect steam temperatures, boiler and unit operation, performance and emissions.

A comprehensive approach to performance improvement and emissions reduction of a tangentially-fired unit is described in this paper. Technical approach to combustion tuning and combustion optimization and achieved results are described and discussed on Part 1 of the paper. Part 2 deals with Electrostatic Precipitator (ESP) performance improvement and sootblowing optimization.

INTRODUCTION

Comprehensive approach to performance improvement and emissions reduction of a utility boiler, involving combustion tuning and combustion optimization, sootblowing optimization and removal of operating constraints, is needed to achieve best results. Combustion optimization of a pulverized coal-fired boiler is a complex process, requiring in-depth knowledge of a combustion process in a utility boiler, operation of the firing system, and other factors affecting emissions and performance. Combustion tuning is performed by manipulating burner settings until a more uniform air and fuel distribution is achieved between the burners. A back-end multi-point gas extraction grid is typically used to provide information on spatial stratifications in CO, excess O₂ and NO_x over the economizer gas exit duct.

Slagging, fouling and sootblowing are important parameters that need to be considered while performing combustion optimization. This is because they affect steam temperatures and

¹ Prepared for Presentation at the 30th International Technical Conference on Coal Utilization and Fuel Systems, April 2005, Clearwater, Florida.

attemperating sprays and, therefore, boiler and unit operation and performance. These parameters also affect furnace cleanliness and, therefore, furnace exit gas temperature (FEGT), which affects NO_x emissions.

UNIT DESCRIPTION

Bridgeport Unit 3 is a 400 MW tangentially-fired, four-corner subcritical single-reheat unit that was converted to burn a variety of low-sulfur coals and retrofitted with a CE TFS2000R low-NO_x firing system. The low-NO_x system consists of three levels of tiltable and yawable upper SOFA registers (Levels A, B and C), three levels of tiltable and yawable lower SOFA registers (Levels A, B and C), two levels of CCOFA registers (Levels A and B), and five elevations (A to E) of low-NO_x burners.

The combustion system utilizes a combination of staged combustion, blanket offset air and over-fire air to reduce NO_x. Under staged combustion, a portion of the secondary air is diverted away from the main burner zone to the CCOFA and SOFA ports located above the main windbox. The concentric secondary air (SA) compartments in each furnace corner utilize blanket air that permits SA to be diverted away from the coal stream. This enhances air staging for NO_x control. In addition, a blanket of air along the furnace walls is created that provides an oxidizing environment next to the waterwalls. All SA registers and burner nozzles in the main windbox can be tilted 30 degrees above or below horizontal position.

Coal to the burners is supplied by five exhaustor type pulverizers (A to E), where A is the top mill, feeding the top burner elevation, and E is the bottom mill, feeding the bottom burner elevation. The excess O₂ level is measured by six O₂ probes located in two economizer gas exit ducts (three probes per duct).

Unit 3 is under stringent NO_x and SO₂ limits from the State of Connecticut. During the Ozone Transport Season (OTS), NO_x limit is 0.150 lb/MBtu, while the SO₂ limit is 0.330 lb/MBtu on a quarterly basis. The unit complies with emission limits by firing an imported coal, characterized by a low heating value (HHV), low Hardgrove grindability index (HGI), high moisture content, low ash content, low Nitrogen, high ash iron content, and low ash softening temperature.

The unit is equipped with a SO₃ flue gas conditioning (FGC) system which injects SO₃ the air preheater (APH) inlet to improve ESP performance. Furnace is cleaned by 48 wall-blowers, arranged in 3 elevations, while 18 retractable sootblowers are employed to clean convection pass of the boiler.

TECHNICAL APPROACH

A comprehensive approach, involving combustion tuning, combustion optimization, ESP collection performance improvement study and sootblower characterization and sootblowing optimization was employed.

Combustion Optimization

Pioneered by the Lehigh University Energy Research Center (ERC), combustion optimization represents an alternative to hardware modifications for emissions reduction or performance improvement or it can be used in conjunction with hardware modifications to maximize their effectiveness. The ERC combustion optimization method is based on

modifications to the boiler control settings with the objective to achieve the desired optimization goal, such as: target NO_x level, best performance, or lowest mercury emissions, while satisfying imposed operating, performance and environmental constraints. To date, combustion optimization has been applied at more than 150 power plants in the U.S. to minimize emissions and optimize unit performance.

Due to a large number of boiler control parameters that are typically involved in a combustion optimization process, manual determination of optimal boiler control settings is typically not possible. A systematic approach, consisting of parametric field tests, correlation of test data using artificial neural networks (ANNs), and determination of optimal boiler settings by a mathematical optimization algorithm, is needed.

Based on more than ten-year experience with combustion optimization of utility boilers, the ERC has developed a practical procedure for combustion optimization that is based on a deep understanding of the underlying physics (combustion process in a PC-fired boiler and factors affecting it). The ERC combustion optimization approach is divided into the seven steps as follows:

- Step 1: Test Preparations
- Step 2: Combustion Tuning
- Step 3: Parametric Tests and Creation of Database
- Step 4: Correlation of Test Data
- Step 5: Determination of Optimal Boiler Control Settings
- Step 6: Implementation of Optimal Control Settings
- Step 7: Maintaining Optimal Control Settings

The steps in the ERC approach are described in detail in many technical papers, References [1 to 10].

Boiler OP

An intelligent combustion optimization software **Boiler OP** was developed by the ERC and Potomac Electric Power Company (PEPCO) to automate creation of the database, correlation of test data, and determination of the optimal boiler control settings (Steps 3, 4 and 5). **Boiler OP** combines an expert system, neural networks and an optimization algorithm into a single program, running under Windows operating system. The code employs a graphical user interface which allows user to setup the code and model the specific boiler, select optimization goal and operating constraints, view optimization results, and perform trade-off studies. Details on **Boiler OP** can be found in References [11 to 14].

Achieved Results

The ERC combustion optimization approach and **Boiler OP** were used to optimize more than 30 utility boilers, tangentially- and wall-fired, ranging in size from 80 to 750 MW and firing eastern and western fuels, including PRB, fuel blends, including co-firing with fuel oil, natural gas and coke oven gas.

Although NO_x reduction represents traditional combustion optimization goal, ERC has also applied combustion optimization to improve unit performance, reduce slagging and minimize mercury emissions from fossil-fired utility boilers. The achieved results are the following:

1. NO_x emissions reduction in the 5 to 35 percent range.
2. Performance improvement in the 50 to 120 Btu/kWh range.
3. Mercury emission reduction in the 30 to 80 percent range.

Steps in the ERC Combustion Optimization Approach

Prior to beginning testing, it is important to conduct **Step 1**, i.e., inspect and calibrate instrumentation to ensure representative and accurate readings, inspect the boiler and combustion system to ensure burners, dampers and actuators are in a good mechanical condition, the coal pipe flows are balanced, and the mills are adjusted properly and are in a good state of maintenance.

Combustion tuning (**Step 2**) is an important and necessary step, which maximizes benefits of the combustion optimization program. It involves balancing of air and fuel between individual burners, setting up the mills for best grind and, if necessary, balancing coal flow between the individual coal pipes. Parametric testing (**Step 3**) is performed after **Steps 1 and 2** are completed.

Parametric tests (**Step 3**) are conducted to build a database which relates the effect of boiler operating parameters on emissions and performance parameters such as NO_x, CO, opacity, LOI, Hg, opacity, steam temperatures, desuperheating sprays and unit heat rate. Parametric tests are performed by varying one parameter at the time and keeping the remaining parameters fixed. This systematic approach provides information on the effect of each test parameter on emissions and performance. This is very helpful in understanding the complex relationships between boiler and burner control settings, emissions and unit heat rate and helpful when diagnosing combustion and emission-related problems. A reference or baseline test is conducted at the beginning of each test day. The purpose of the reference test is to establish a point of reference for comparisons, factor out any day-to-day variations caused by the fuel quality and slagging changes, and normalize test data.

Combustion optimization relies on a data-based model describing the effect of boiler control settings on emissions, performance and other parameters of interest. In **Step 4**, the data-based model is created by using the data collected during parametric testing. Artificial neural networks (ANNs) are used to develop correlations between the boiler control settings, emissions, and performance parameters.

Performance of the resulting ANN model is influenced significantly by the quality of the data used to create it. In developing ANN models using test data, it must be kept in mind that ANNs: (a) learn from the data, and (b) cannot distinguish the good data from the bad. Therefore, before creating an ANN model, it is important to remove outliers from the database since those could result in incorrect trends and decrease the overall ANN accuracy. After verifying the data, an ANN model is created by training it on a training data set. ANN predictions are verified for accuracy and trending using a verification data set.

To create a good ANN model, it is crucial to perform a sufficient number of parametric tests over a range of boiler operating conditions that is considerably wider than the normal operating range. This is needed for two very important reasons: (a) to build good correlations between operating parameters, emissions and performance parameters, (b) to ensure the global optimum is included within the test range. A too narrow test range might not contain the global optimum. In such a case, the obtained "optimal settings" will represent the local, rather than the global optimum, and maximum combustion optimization benefit will not be achieved.

Once the ANN model is developed and tested, the optimal solution (a set of optimal boiler control parameters), satisfying optimization goal and imposed constraints, is obtained by employing a mathematical optimization algorithm (**Step 5**). The Nelder-Meade Downhill Simplex Method is used by the **Boiler OP** code.

In the ERC approach options available for implementation of the optimal settings determined by the **Boiler OP (Step 6)** include:

- ! Open-Loop Operator Advisory,
- ! Program Optimal Settings into the Plant DCS,
- ! Closed-Loop Control for Key Operating Parameters.

In the open-loop advisory mode, **Boiler OP** is using real-time plant data to provide advice to the operator on the optimal settings and information on the emission and performance penalties for not operating at optimal settings. Alternatively, the optimal settings, obtained by **Boiler OP**, can be programmed into the plant DCS to provide automatic control. To deal with the daily variations in fuel quality and maintenance status of the combustion equipment, a closed-loop trim control for key operating parameters (such as, SOFA register opening or excess O₂ level) can be implemented. In such arrangement, the value of a key parameter is modulated to maintain the desired NO_x emission level. This provides a cost-effective alternative to a full closed-loop network control, where all boiler control parameters are incorporated in the closed-loop control strategy.

As discussed above, determination of the optimal boiler control settings is a challenging task. Maintaining optimal settings on a long term (**Step 7**) can be equally challenging. For example, as the maintenance condition of a firing system degrades over time, CO emissions increase. This imposes a tighter operating constraint and forces the plant control system or a closed-loop neural network controller to select a higher optimal O₂ level, degrading therefore, NO_x reduction performance. Also, an increase in LOI, due to the degradation in mill performance, can result in increased opacity levels which, might result in higher NO_x emissions. Although, the adaptive closed-loop neural network controllers can deal with the abovementioned changes, the result of such passive NO_x control strategy is undesirable deterioration of NO_x reduction performance.

To deal with these changes, the ERC recommends a pro-active approach, which focuses on maintaining top performance of the boiler firing, milling and control systems. The ERC recommends periodic combustion tuning to maintain best performance of the firing system and minimize operating constraints, periodic coal fineness tests to track mill performance, and periodic fine-tuning of the control system. For best NO_x reduction performance, the ERC also recommends inspection of the combustion hardware during the spring outage, followed by the combustion tuning before the start of the OTS.

Combustion Tuning

Combustion tuning was performed to reduce high CO levels, encountered during unit characterization and pre-outage tests. CO concentration was measured by traversing a gas sampling probe over a total of 24 points (8 x 3 grid) in each of the two economizer gas exit ducts (South and North). A portable gas analyzer was used to measure CO and excess O₂ concentrations in the flue gas. Measured CO and O₂ concentrations are presented in [Figures 1a](#) and [1b](#) and [2a](#) and [2b](#). The results indicate severe stratification in CO and O₂ concentration in the upper North and upper South corners of both ducts.




Figure 1: Spatial Distribution in CO Before and After Combustion Tuning




Figure 2: Spatial Distribution in O₂ Before and After Combustion Tuning

Based on these measurements and per ERC recommendation, the station personnel inspected rifiers in all coal pipes during the unit outage and replaced those that were severely damaged by erosion. Eroded rifiers resulted in uneven distribution of coal flow between the coal pipes. This imbalance in coal flow distribution is suspected to be the main reason for the severe spatial stratification in CO and O₂ concentration, measured at the economizer gas outlet. A permanent flue gas sampling 8x4 grid was installed during the outage to allow for future combustion tuning.

The permanent gas sampling grid was used after the unit outage to measure spatial variation in CO and O₂ concentration over the economizer duct cross-section. Although, as a result of the improvement in the maintenance condition of the firing system during the unit outage, there was an overall improvement in measured CO and O₂ stratification, a high CO pocket (400-1,000 ppm) still existed in the North-East corner of the North duct. In the South economizer duct, the CO was lower (70 –100 ppm).

Combustion tuning was performed after unit outage. It involved modifications to the SA register settings at each of the four furnace corners, and manipulations of the SOFA register openings and SOFA yaws.

Measured CO and O₂ concentrations, after unit outage and boiler tuning are presented in [Figures 1c and 1d and 2c and 2d](#). The results indicate very uniform CO and O₂ concentrations in both the North and South economizer ducts. Also, the average CO levels, measured after boiler tuning, were significantly lower compared to the pre-outage values. This allowed lowering of the average excess O₂ level without having adverse effect on CO emissions, which were maintained in the 40 ppm range. With lower O₂, the full-load NO_x emissions were reduced by 10 percent. This reduction in baseline NO_x and CO emissions has maximized combustion optimization benefits.

Also, with lower CO emissions, it was possible to remove biases and constraints implemented into combustion control system to compensate for high CO emissions. Bias for windbox-to-furnace differential pressure (ΔP_{wb}) was removed, which allowed operation at lower ΔP_{wb} values, further lowering NO_x emissions. Also, with lower CO, it was possible to raise SOFA tilts and achieve additional NO_x reduction. Previously, due to the high CO, SOFA tilts were locked in horizontal position.

Combustion Optimization Results

The objectives of the Bridgeport combustion optimization study included the following:

- Determine baseline NO_x levels at full-load, reduced load (4-mill operation) and minimum load conditions.
- Characterize the unit in terms of emissions and performance.
- Determine optimal combinations of boiler control settings at full-load conditions for a range of target NO_x, emissions levels below 0.150 lb/MBtu, resulting in minimum unit heat rate, subject to the CO and opacity emissions constraints.
- Determine improved boiler operating settings for 4mill operation, for various mill firing configurations, and for minimum-load.

Determination of optimal boiler control settings over a range of target NO_x levels at full-load conditions is important to Bridgeport because it allows optimum operation at aggressive NO_x

levels during the OTS, when trading of emission allowances is financially beneficial, and also optimum unit operation at higher NO_x emission levels for the rest of the year.

Full-Load Operation

Table 1 provides a summary of key boiler operating parameters for a tangentially-fired boiler and the parameters tested and optimized at Bridgeport. The CCOFA register and the top mill bias were partially tested, using the maximum bias available in the firing control system. However, these two parameters had a negligible effect on NO_x and were, therefore, not included into combustion optimization program. No information on primary air velocities was available for this unit and, therefore, the effect of this parameter was not tested.

Table 1
Key Operating Parameters for a Tangentially-Fired
Boiler and Parameters Tested and Optimized at Bridgeport

PARAMETER	TESTED	OPTIMIZED
Economizer O ₂	Yes	Yes
Windbox-to-Furnace Differential Pressure	Yes	Yes
SOFA Register Opening and Bias	Yes	Yes
Burner Tilt Angle	Yes	Yes
SOFA Tilt Angle	Yes	Yes
CCOFA Register Opening	Partially	No
Mill Bias	Partially	No
Primary Air Bias	No	No

Fifty-nine parametric and baseline tests were performed. For each test point, operating data were collected over a 15-minute time interval, once a steady state operation of the unit was achieved. Sootblowing was put on hold while parametric tests were performed to factor out its effect on steam temperatures. A combination of the data collected automatically by the plant data acquisition system (DAS) and manually collected data was used to create a database. Off-line data included fly ash carbon content (LOI), determined from the manually collected ash samples and calculated values of net unit heat rate. Changes in net unit heat rate with respect to baseline conditions were calculated using a heat and mass balance model of the unit and a differential heat rate method developed by the ERC.

A database was created from the test results and used to determine baseline emission and performance characteristics of the unit and develop an ANN model of the unit. After verification, the ANN model was used in conjunction with the downhill simplex optimization algorithm to determine optimal boiler control settings over a range of target NO_x emission levels.

Before parametric tests were conducted, concerns were raised regarding the applicability of the combustion optimization approach to foreign coals and ultra-low-NO_x emission levels. However, the results of this project showed that even under these extreme conditions the ERC combustion optimization approach worked well, producing relationships and trends between the emissions, performance, and boiler operating parameters that were the same as for the U.S. bituminous and sub-bituminous coals.

Figures 3 to 6 show relationships between NO_x emission rate and boiler control parameters. The NO_x and CO vs. excess O₂ level relationships are presented in Figure 3. As expected, results show that NO_x emission rate decreased and CO concentration increased as excess O₂ level was reduced. For baseline O₂ level of 2.85 percent, CO concentration was low, below 40 ppm. CO increased to 100 ppm as O₂ was decreased to 2.2 percent. Figure 4 shows that windbox-to-furnace pressure differential (ΔP_{WB}) has a large effect on NO_x emission rate, which decreased as ΔP_{WB} was decreased, while CO was virtually unaffected by changes in ΔP_{WB} . This is because a decrease in ΔP_{WB} results in lower air velocity at burner throat, less vigorous mixing between air and coal, and lower NO_x emission rate.

A relationship between the lower SOFA (LSOFA) register opening and NO_x emission rate is presented in Figure 5. As expected, NO_x is reduced as LSOFA register opening is increased with most of the reduction occurring during the first 50 percent of the LSOFA register opening. A further increase in LSOFA results in a small decrease in NO_x. The results also show that LSOFA Level A (lowest elevation) is the most effective in reducing NO_x, while the top LSOFA elevation (Level C) is the least effective. Figure 5 also shows the effect of excess O₂ on NO_x. The effect of main burner tilt and excess O₂ level on NO_x is presented in Figure 6. Results are in line with expected trends, i.e., NO_x emission rate increases with an increase in burner tilt angle and decreases with a reduction in excess O₂ level.

Although changes in NO_x emission rate caused by changes in boiler operating parameters are very small for this ultra-low NO_x situation, the **Boiler OP** code created a high fidelity ANN model. Comparison between measured and predicted values of NO_x emission rate, presented in Figure 7, shows the excellent agreement between measurements and predictions. Such good agreement is a prerequisite for realistic optimization results.

Optimization results are presented in Figures 8 to 11. Figure 8 shows a relationship between the target NO_x emission level and net unit heat rate deviation ΔHR_{net} (expressed as a difference from the minimum value from all tests) over a range of NO_x levels from 0.120 to 0.160 lb/MBtu. The NO_x level range is narrow because of the constraints imposed on CO, stack opacity, FEGT and other operational parameters such as steam temperatures and ΔP_{WB} .

The unconstrained and constrained optimal settings curves are shown. The constrained curve takes into account minimum practical and acceptable excess O₂ levels and, therefore, for the same target NO_x level it results in a higher unit heat rate compared to the unconstrained optimal curve. The results show that for a target NO_x level of 0.130 lb/MBtu, optimal constrained boiler operating settings result in heat rate savings of approximately 65 Btu/kWh with respect to the baseline operating conditions. The constrained solution was obtained upon the request from plant operations, who were concerned that a too low value of excess O₂ level could result in locally reducing conditions and waterwall wastage.

The shape of the optimal settings curve is typical of highly reactive coals where LOI is low. In this case, heat rate improves as target NO_x is reduced due to a decrease in stack loss and reduction in attemperating sprays. For bituminous coals where LOI is high, the heat rate typically increases as target NO_x is reduced. According to the results from Figure 8 for Bridgeport, there is no heat rate benefit for operating at higher NO_x levels. The optimal operating point for this unit, considering performance only, is in the 0.125 to 0.130 lb/MBtu NO_x




Figure 3: Effect of Excess O₂ and NO_x and CO Emissions




Figure 4: NO_x and CO Emissions as Functions of Windbox-to-Furnace Pressure Differential




Figure 5: NO_x Emission Rate as a Function of LSOFA Opening and Excess O₂ Level




Figure 6: NO_x Emission Rate as a Function of Burner Tilt Angle




Figure 7: Comparison of Predicted and Measured NO_x Values




Figure 8: Net Unit Heat Rate as a Function of Target NO_x Level




Figure 9: Optimal O₂ and Windbox-to-Furnace Pressure Differential Settings as Functions of Target NO_x Level




Figure 10: Optimal LSOFA Damper Openings as Functions of Target NO_x Level




Figure 11: Optimal Burner Tilt Angle as a Function of Target NO_x Level

range. However, outside of the OTS, the optimal operating point is at higher excess O₂ and higher target NO_x level. This is because waterwall wastage at higher O₂ is lower, compared to the low-O₂ operation and optimal operating point represents a trade-off between fuel savings and increase in maintenance cost.

The optimal boiler control settings for the constrained case are presented in Figures 9 to 11. Optimal excess O₂ and ΔP_{WB} values are presented in Figure 9 for a target NO_x range from 0.125 to 0.150 lb/MBtu. Optimal LSOFA register settings for Levels A, B and C are presented in Figure 10, while the optimal main burner and LSOFA tilt angles are presented in Figure 11. The optimal boiler operating settings for the OTS and the rest of the year are summarized in Table 2.

Part-Load Operation

In addition to the full-load parametric tests a series of tests were performed at reduced load conditions to investigate potential improvements at 3/4 load (4-mill operation) and minimum-load (3-mill operation). With 4 mills in service, testing was performed with A-mill and C-mill out of service. The A-mill is the top mill and NO_x emissions are known to decrease when fuel is biased to the lower mill elevations. Taking the C-mill out of service for maintenance, results in split-fire condition. According to the plant experience, this firing configuration also results in reduced NO_x emissions. With three-mill in service, testing was performed for the A-mill and B-mill out of service configuration with both mills in stand-by mode and for the A-mill in stand-by mode and B-mill shut down. Prior to part-load tests, the maximum achievable unit load with four mills in service was 330 MW. Further unit-load increases were limited by high CO emissions.

Table 2
Optimal Boiler Operating Settings

Test Parameter	Boiler OP Results		Baseline Conditions
	Ozone Season	Rest of the Year	
Economizer Excess O ₂ [%]	2.45	2.85	2.87
Burner Tilt [deg.]	-12.5	-12.0	-14.8
LSOFA Tilt [deg.]	10.0	10.0	10.4
LSOFA Registers A, B, C [%]	100/100/100	40/80/90	100/100/100
Windbox-to-Furnace Differential ["wg]	5.5	5.5	6.1
Predicted Values			
NO _x Emission Rate [lb/MBtu]	0.131	0.149	0.135
Change in Heat Rate [Btu/kWh]	21	88	86
Fly Ash LOI [%]	1.9	1.6	1.7
CO [ppm]	101	65	47

The effect of the following parameters was tested: excess O₂, LSOFA, CCOFA and auxiliary air register openings, SOFA and burner tilts, ΔP_{WB} set-point, and primary air flow through the out-of-service mills. Fly ash samples were collected similar to the full-load tests. Constraints were similar to those used in the full-load combustion optimization tests. Steam temperatures were constrained to values above 980°F.

Based on the test results, changes to the mill and boiler operating settings were identified and implemented which resulted in CO emissions decreasing down to the 60 to 70 ppm range. With drastically reduced CO emissions, it was possible to increase the maximum unit power output for 4-mill operation from 330 MW to 375 MW, a 45 MW increase. Test results are summarized in [Table 3](#).

Table 3
Improvements for the 4-Mill Operation

Parameter	A-Mill Out of Service		C-Mill Out of Service	
	As-Found	Recommended	As-Found	Recommended
Excess O ₂ [%]	3.00	2.84	2.97	2.69
Load [MW _{net}]	338	376	339	372
NO _x [lb/MBtu]	0.132	0.161	0.122	0.119
CO [ppm]	300 to 800	70 to 100	70	70
Fly Ash LOI [%]	0.7	1.3	0.6	0.7

The main goal of minimum-load testing was to minimize excess air flow requirements and reduce NO_x emissions. The excess O₂ was gradually reduced, while other boiler control settings were adjusted to control CO. At minimum-load conditions, the LSOFA registers were found to have a first order impact on CO and NO_x emissions. Also a setpoint for ΔP_{WB} was increased to provide more air to the LSOFAs. Results are summarized in [Table 4](#).

Table 4
Improvements for the 2-Mill Operation

Parameter	As-Found	Recommended PA on Both Mills	Recommended PA on A-Mill Only
LOSFAs A/B/C [%]	24/50/75	0/0/50	0/50/100
CCOFAs A/B [%]	30/0	0/0	0/0
ΔP_{WB} ["wg]	3.1	2.8	2.9
Excess O ₂ [%]	7.60	5.23	5.76
Load [MW _{net}]	146	144	142
NO _x [lb/MBtu]	0.156	0.134	0.124
CO [ppm]	85	82	84
Stack Opacity [%]	7.5	5.9	6.1
Fly Ash LOI [%]	3.8	Not Collected	3.1

As shown in Table 4, the excess O₂ was reduced from 7.6 percent to 5.2 - 5.8 percent range. NO_x emissions were reduced from 0.156 to 0.134 and 0.124 lb/MBtu for the B-mill in stand-by mode and B-mill with no primary air (PA) mode, respectively (a 21 percent improvement). CO emissions remained the same, while stack opacity was improved. A comparison of the as-found and recommended O₂ control curves and resulting NO_x emissions over a range of unit loads is presented in Figure 12.




Figure 12: O₂ Control Curve and NO_x Emission Level as Functions of Unit Load

Implementation of Optimal Settings

The optimal boiler control settings are implemented at Bridgeport using a cost-effective on-line, open-loop **Boiler OP** Operator Advisor. The custom version of the **Boiler OP** on-line advisory was developed and interfaced with the plant data acquisition system, using a Dynamic Data Exchange (DDE) interface. The main operator screen is presented in Figure 13. The actual and optimal values of boiler control settings are presented, along with the status of each of the on-line values. Deviations from optimal values are presented in a graphical form. In case of a deviation, an expert system displays advice to the operator. Predicted deviations in NO_x, heat rate, LOI and CO due to actual operating settings being different from optimal values, are shown in numeric and graphical forms. The objective is to have a zero or minimum deviation, i.e., to operate with actual boiler control settings as close as practically possible to the optimal settings.




Figure 13: Boiler OP Operator Advisor

The two new features of the current **Boiler OP** Advisory are the What-If capability and capability to adapt to changes in coal quality. The What-If capability allows the user to manually input values for some or all of the parameters and determine their effect on emissions, performance, LOI and CO. This option can be used while the code is running on-line.

Since fuel quality is variable at Bridgeport, an option was added to the **Boiler OP** Operator Advisory that allows variations in NO_x due to changes in fuel quality to be taken into account when determining optimal operating conditions.

CONCLUSIONS AND RECOMMENDATIONS

Combustion optimization was performed by the ERC at Bridgeport Harbor Unit 3 during the months of November and December 2004, using the intelligent optimization code **Boiler OP**. The combustion optimization project included inspection of the unit, combustion tuning of the low-NO_x firing system, parametric testing to create a database, building of an ANN model of the plant, determination of optimal control settings and development and implementation of the customized on-line open-loop Operator Advisory. This project was executed in combination with a sootblowing optimization project, also, performed by the ERC. Support for the project was provided by station engineers and Operations personnel.

The following conclusions and recommendations were issued:

- Average full-load baseline NO_x emissions with five mills in service were found to be 0.135 lb/MBtu.
- The key operating parameters, affecting NO_x emissions at Bridgeport, in descending order of importance are: excess O₂, LSOFA registers, burner and SOFA tilts and windbox-to-furnace differential pressure. NO_x emissions were also found to be strongly sensitive to fuel quality, which is very variable at Bridgeport.
- Unit heat rate was found to be strongly dependent on the excess O₂ level and slightly dependent on the burner and LSOFA tilts and average LSOFA register opening.
- Optimal constrained boiler control settings were developed for a range of target NO_x emission levels by limiting minimum value of excess O₂ level to avoid operation at extreme reducing environments in the furnace.
- The shape of the optimal settings curve is typical of highly reactive coals where LOI is low. In this case, heat rate improves as target NO_x is reduced due to a decrease in stack loss and reduction in attemperating sprays. The optimal operating point for this unit, considering performance only, is in the 0.125 to 0.130 lb/MBtu NO_x range.
- During the OTS and target NO_x level of 0.130 lb/MBtu, optimal constrained boiler operating settings result in heat rate savings of approximately 65 Btu/kWh with respect to the baseline operating conditions.
- The reduction in NO_x emission rate and improvement in unit performance, associated with these optimal operating settings represent total savings of \$283,600 (assuming fuel cost of \$1.25/MBtu, unit heat rate of 10,000 Btu/kWh, unit capacity factor of 0.85, and NO_x credit of \$2,000/ton).
- Due to the lower waterwall wastage at higher O₂ levels, the optimal operating point outside of the OTS is at higher excess O₂ and higher target NO_x level. The optimal excess O₂ level for this case represents a trade-off between fuel savings and increase in maintenance cost.
- From the part-load tests with four mills in service (A-Mill or C-Mill off), gains in load generation of more than 45 MW were achieved by manipulating the boiler control settings and eliminating the stand-by mode on the out-of-service mill.

- At minimum-load conditions (140 MW), reduction in NO_x emissions of more than 20 percent was achieved with A-Mill and B-Mill out-of-service and no primary air flowing through the B-Mill.
- The economizer excess O₂ control curve was modified, which resulted in O₂ reductions of the order of 25 percent and a reduction in NO_x emissions over the load range.

ACKNOWLEDGEMENTS

The authors acknowledge enthusiastic effort of the engineering and operating staff from Bridgeport Generating Station who contributed in the planning, coordination and execution of this project.

REFERENCES

1. Sarunac, N., C. E. Romero and E. K. Levy, "Combustion Optimization: Part 1 – Methodology and Tools," Presented at Combustion Canada 2003 Conference, September 21-24, 2003, Vancouver, BC, Canada.
2. Romero, C. E., N. Sarunac and E. K. Levy, "Combustion Optimization: Part 2 – Results of Field Studies," Presented at Combustion Canada 2003 Conference, September 21-24, 2003, Vancouver, BC, Canada.
3. Romero, C. E., N. Sarunac, H. Bilirgen, and E. K. Levy, "Combined Optimization for NO_x Emissions, Unit Heat Rate and Slagging Control with Coal-Fired Boiler," Presented at the 28th International Technical Conference on Coal Utilization & Fuel Systems," Clearwater, Florida, March 10-13, 2003.
4. Sarunac, N., C. E. Romero, E. K. Levy, and W. C. Weston, "Anatomy of a Successful Combustion Optimization Project," The US EPA/DOE/EPRI Combined Power Plant Air Pollutant Control Symposium: "The MEGA Symposium," August 20-23, 2001, Chicago, Illinois.
5. Romero, C. E., N. Sarunac, R. Conn, and E. K. Levy, "Combustion Optimization for NO_x Control with Slagging Constraints," The US EPA/DOE/EPRI Combined Power Plant Air Pollutant Control Symposium: "The MEGA Symposium," August 20-23, 2001, Chicago, Illinois.
6. Romero, C. E., E. K. Levy and N. Sarunac, "Impacts of Combustion Optimization on Power Plant Heat Rate," EPRI's 12th Heat Rate Improvement Conference," Dallas, Texas, January-February, 2001.
7. Romero, C. E., N. Sarunac, J. Luk, K. C. Chan, S. Kho, A. Frank, and B. Benaissa, "Combustion Optimization of a Load-Following Boiler with Flue Gas Recirculation Capabilities." IJPGC 2000-15057, 2000 International Joint Power Generation Conference, Miami Beach, Florida.
8. Levy, E. K., T. Eldredge, C. E. Romero, and N. Sarunac, "I&C Enhancements for Low NO_x Boiler Operation," Presented at the 9th International Joint ISA POWID/EPRI Instrumentation & Controls Conference in St. Petersburg, Florida, June 1999.
9. Sarunac, N., C. E. Romero, E. K. Levy, et al., "Performance Optimization of R. P. Smith Unit 4," Presented at EPRI 1998 Heat Rate Improvement Conference, Baltimore, Maryland, September 1998.
10. Romero, C. E., T. Eldredge and E. K. Levy, "Combustion Optimization of Hudson Station 2," Presented at the EPRI 1988 NO_x Controls for Utility Boilers Workshop, Baltimore, Maryland, 1988.

11. Maines, P., D. Schnetzler, A. Bilmanis, S. Williams, D. Eskenazi, T. Schmitt, T., Eldredge, N. Sarunac, and E. K. Levy, "Combustion Optimization of Low NO_x Burners at PEPCO's Morgantown Station," Presented at 1995 EPRI/EPA Joint Symposium on Stationary Combustion NO_x Control, Kansas City, Missouri, May 1995.
12. Romero, C. E., N. Sarunac and E. K. Levy, "Field Results from Application of Boiler OP to Utility Boilers." First Annual Joint ISA POWID/EPRI/DOE Instrumentation and Controls Conference, San Antonio, Texas, 2000.
13. Cramer, D., S. Williams, N. Sarunac, E. K. Levy, "Application of Boiler OP to Utility Boilers: Field Results," Presented at EPRI 1998 NO_x Controls for Utility Boilers Workshop," Baltimore, Maryland, August 1998.
14. Sarunac, N., M. D'Agostini, J. Miles, T. Eldredge, S. Steele, S. Williams, "Boiler OP: Intelligent Software for Combustion Optimization," Presented at the POWER-GEN International '96 Conference, Orlando, Florida, December 1996.
15. Sarunac, N., C. E. Romero, B. Clements, R. Pomalis, J. Henrikson, W. Cylwa, and J. Luk, "Sootblowing Optimization: Part 1 - Methodology, Instrumentation and Determination of Section Cleanliness," Presented at Combustion Canada 2003 Conference, September 21-24, 2003, Vancouver, BC, Canada.
16. Sarunac, N., C. E. Romero, J. Shan, X. Bian, B. Clements, R. Pomalis, J. Henrikson, W. Cylwa, and J. Luk, "Sootblowing Optimization: Part 2 – Sootblower Characterization and Implementation of an Intelligent Sootblowing Advisor," Presented at Combustion Canada 2003 Conference, September 21-24, 2003, Vancouver, BC, Canada.
17. Sarunac, N. and C. Romero, "Sootblowing Optimization and Intelligent Sootblowing," Presented at 4th Intelligent Sootblowing Workshop, Houston, Texas, March 2002.
18. Sarunac, N., C. E. Romero and H. Bilirgen "Optimization of Sootblowing in Utility Boilers," EPRI Heat Rate Conference, Birmingham, Alabama, January 28-30, 2003.
19. Sarunac, N., C. E. Romero and E. K. Levy, "Combined Optimization for NO_x Emissions, Unit Heat Rate and Slagging Control with Coal-Fired Boilers," 28th International Technical Conference on Coal Utilization and Fuel Systems, March 9-14, Clearwater, Florida.